Commissioning of Yamuna Nagar Super Thermal Power Plant

199. SHRI S. S. SURJEWALA: Will the Minister of POWER be pleased to state:

(a) whether the Super Thermal Power Plant constructed at Yamuna Nagar by NTPC has got final clearance by Government;

(b) whether the financial tie-up for construction of the plant has been reached; if so, the details thereof;

(c) what is the quantum of power that Haryana will get from this plant and on what terms;

(d) what is the cost of the plant which is to be borne by the Government of Haryana; and

(e) by when the plant is likely to be completed?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU): (a) and (b) The Yamunanagar Thermal Power Project (4x210 MW) was proposed to be implemented by the National Thermal Power Corporation (NTPC) as a Central Sector project. However, because of financial constraints, it is now envisaged to implement the project as a joint venture by NTPC and the Haryana State Electricity Board (HSEB) with a private co-promoter. Necessary clearance from the Government for implementation of the project is to be obtained by the Joint Venture Company (JVC) after selection of the co-promoter.

(c) and (d) Supply of power to be generated from the project would be as mutually agreed to by the JVC with the HSEB. After the JVC is formed and the respective shares of the Co-promoters is arrived at would the contribution of the Government of Haryana towards the project be determined.

(e) The commissioning schedule could be anticipated only after the JVC is formed and clearance from the Government obtained.

Inquiry into power break-down in Delhi

200. SHRI GAYA SINGH:
SHRI N. E. BALARAM:
SHRI SUNDER SINGH BHANDARI:
CHOWDHARY HARI SINGH:

Will the Minister of POWER be pleased to state:

(a) whether a high-level inquiry has been ordered into the northern grid failure plunging Delhi and large parts of Rajasthan and Uttar Pradesh into darkness on the 6th June, Mid-night;

(b) if so, the details thereof;

(c) whether the said committee has submitted its report;

(d) if so, the details of the findings thereof; and

(e) what concrete steps are being taken to avoid frequent power cuts in Delhi during the recent months?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU): (a) and (b) The Government has appointed a Committee of two experts namely S/Shri V. B. Eswaran and A. K. Sah to look into the causes of grid disturbance in the Northern Region on the night of 6th/7th June, 1993 and to suggest remedial measures.

(c) The Committee has submitted an interim report on 19th July, 1993.

(d) According to the interim report of the Committee, a fault was initiated either at 400 KV switch yard of the Singrauli Super Thermal Power Station or on the Singrauli-Kanpur 400 KV transmission line. The bus bar protection at Singrauli Switch-yard failed to operate which caused the tripping of all the generating units at Singrauli and Rihand Super Thermal Power Stations leading to the Grid failure.